



Organic Analysis Summary - LEACHATE WATER

Client: VersaFlex, Inc.
686 S Adams St
Kansas City, KS 66105

Testing Standard: NSF/ANSI 61
Year: 2016

Product Type: Polyrea

Section: 5

Model: AquaVers 405 - Pipe

Project #: 17B0181

Date Issued: 3/28/2017

Attention: John Winfrey

Purpose of the test:

This report describes the results of the representative samples of AquaVers 405 - Pipe for compliance with the requirements of NSF/ANSI 61 Section 5 - 2016. Test results for organic compounds were normalized following NSF/ANSI 61 - 2016 and compared to the Maximum Concentration Limit (MCL) as specified in Table D of the NSF/ANSI 61 - 2016 for Drinking Water Criteria.

Concluding Summary:

Based On the Normalized concentration from laboratory number17B0181 the test sample of the AquaVers 405 - Pipe submitted by VersaFlex, Inc. met the requirements of NSF/ANSI 61 Section 5 - 2016 for a nominal pipe diameter of 2.75 inches as specified in NSF/ANSI 61 - 2016.

We certify that all portions of each test performed were under continuous and direct supervision of Truesdail Laboratories and that the results of the data in this report are true from our test of this material

Respectfully Submitted,
TRUESDAIL LABORATORIES, INC.

Wogderess Berhe
Certification Engineer

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public, and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from these laboratories.