



Certified Product Listing

For:

Drinking Water System Components - Health Effects

Company:

VersaFlex Incorporated
686 S Adams Street
Kansas City, Kansas 66105, United States

Plant Location:

Kansas City, KS, United States

Standards:

NSF/ANSI 61 Section 5

Certificate:

Issued: 04/10/2017
Expires: 12/31/2022

Material/Product:

Polyurea Interior/Lining Barrier System for Tanks, Vessels, Storage Containers that are used for Potable/Drinking Water

Contact Temperature:

60 ± 2°C

Models:

AquaVers 405



Product certified to NSF/ANSI 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.



Material Characteristics:

Minimum pipe diameter (inches): 2.75

Maximum pipe surface area/volume ratio (sq in/L): 90.5

Minimum tank size (gallons): 4000

Maximum tank surface area/volume ratio (sq in/L): 3.6

Maximum dry film thickness per coat (mils): 500

Number of coats: 1

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Total cure time and temperature: 5 min at 77 ± 5 °F up to 24 hr at 77 ± 5 °F

Mix ratio: 1:1 (A:B) by Volume

Colors: VersaFlex 1000 Series Colors

Is this paint/coating system intended to be applied to a pipe? (Y/N): Yes

(1) Certified for use on a new pipe? (Y/N): Yes

(2) Certified for use on a pipe intended for immediate return to service? (Y/N): Yes